



IF

Lead in Drinking Water Analysis Report

Environmental Hazards Services, L.L.C.
7469 Whitepine Rd
Richmond, VA 23237
Telephone: 800.347.4010

Report Number: 21-08-03607

Client: LEW Corp
181 US Hwy 46
Mine Hill, NJ 07803

Received Date: 08/23/2021
Reported Date: 08/30/2021
Sampled By: Krishi Tanna
Tech Certification #:

Project/Test Address: 210133; Indian Fields @ Dayton; 310 Georges Rd; Dayton, NJ 08810

Client Number:
201327

Laboratory Results

Fax Number:
Ext 18 Melissa

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-08-03607-001	IFD-B-01	08/06/2021	HALL ACROSS FROM GYM R	354	08/25/2021	
21-08-03607-002	IFD-S-02	08/06/2021	KITCHEN LEFT	6.84	08/25/2021	
21-08-03607-003	IFD-S-03	08/06/2021	KITCHEN RIGHT	4.66	08/25/2021	
21-08-03607-004	IFD-B-04	08/06/2021	HALL LEFT	59.3	08/25/2021	
21-08-03607-005	IFD-B-05	08/06/2021	HALL RIGHT	76.3	08/27/2021	W01
21-08-03607-006	IFD-S-06	08/06/2021	NURSES	4.85	08/25/2021	
21-08-03607-007	IFD-S-07	08/06/2021	NEXT TO EXIT	<1.00	08/25/2021	

Sample Narratives:

W01: MB exceeded acceptance limit for Pb.

Environmental Hazards Services, L.L.C

Client Number: 201327
Project/Test Address: 210133; Indian Fields @ Dayton; 310 Georges Rd;
Dayton, NJ 08810

Report Number: 21-08-03607

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
-------------------	------------------	-----------------	---------------------	--------------------------	---------------	--------------

Method: EPA 200.8
Analyst: Ailea Cabatbat
Accreditation #: NJ VA008

Reviewed By Authorized Signatory: Melissa Kanode

Missy Kanode
QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion



LABORATORIES
ENVIRONMENTAL HAZARDOUS SERVICES, LLC

ONLINE CLIENT PORTAL AVAILABLE FOR ANALYSIS RESULTS AT: www.leadlab.com

Water Chain-of-Custody Form

SHIP TO: 7469 Winstepine Rd. Richmond, VA 23237

Phone: (800) 347-4010 FAX: (804) 275-4907

Company Name: LEW CORP

Account #: 201327

Address: 181 US Highway 46

City/State/Zip: Mine Hill, NJ 07803

Phone: 908-554-8068

Email: labresults@lewcorp.com

Fax: 908-554-9069

Project Name / Collection Address: INDIAN FIELDS @ DAYTON; 310 GEORGES RD

City/State/Zip: DAYTON, NJ, 08810

Project #: 210133

Sampled by: Krishi Tanna

License # (If Required):

Water Source: (Check One) Public Well Well Tag # (If Applicable):

No.	Client Sample ID	Collection Location (For Kitchen Sink)	Collection Date	Collection Time	Metals			Field Parameters		LAB USE Temp at Time of Receipt
					Lead	Copper	Other	Field pH at time of Collection	Temp. at time of Collection	
1	IFD - B - 01	HALL ACROSS FROM GYM- R	8/6/2021	7:48 AM AM/PM	X					
2	IFD - S - 02	KITCHEN LEFT	8/6/2021	7:52 AM AM/PM	X					
3	IFD - S - 03	KITCHEN RIGHT	8/6/2021	8:00 AM AM/PM	X					
4	IFD - B - 04	HALL - LEFT	8/6/2021	8:06 AM AM/PM	X					
5	IFD - B - 05	HALL - RIGHT	8/6/2021	8:10 AM AM/PM	X					
6	IFD - S - 06	NURSES	8/6/2021	8:16 AM AM/PM	X					
7	IFD - S - 07	NEXT TO EXIT	8/6/2021	8:18 AM AM/PM	X					
8										
9										
10										

Released by: KRISHI TANNA

Signature

K. Tanna

Date/Time: 8/6/2021

Date/Time: 8/23/21

1:08 PM

21-08-03607

Due Date:
08/30/2021
(Monday)
AE



Environmental Hazards Services, L.L.C.
 7469 Whitepine Rd
 Richmond, VA 23237
 Telephone: 800.347.4010

Lead in Drinking Water Analysis Report

Report Number: 21-08-03565

Received Date: 08/23/2021
 Reported Date: 08/26/2021
 Sampled By: Krishi Tanna
 Tech Certification #:

Client: LEW Corp
 181 US Hwy 46
 Mine Hill, NJ 07803

Project/Test Address: 210133; Indian Fields; 359 Ridgr Road; Monmouth Junction, NJ 08852

Client Number:
 201327

Laboratory Results

Fax Number:
 Ext 18 Melissa

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-08-03565-001	IF-S-01	08/06/2021	KITCHEN NEXT TO KETTLE	<1.00	08/25/2021	
21-08-03565-002	IF-KF-02	08/06/2021	KETTLE FILLER KITCHEN	5.87	08/25/2021	
21-08-03565-003	IF-S-03	08/06/2021	SINK IN FRONT OF STOVE	<1.00	08/25/2021	
21-08-03565-004	IF-IM-04	08/06/2021	KITCHEN ICE MACHINE	<1.00	08/25/2021	
21-08-03565-005	IF-S-05	08/06/2021	KITCHEN NEXT TO IM	10.4	08/25/2021	
21-08-03565-006	IF-S-06	08/06/2021	KITCHEN NEXT TO IM	8.59	08/25/2021	
21-08-03565-007	IF-S-07	08/06/2021	KIT NEXT TO DISHWASH L	19.1	08/25/2021	
21-08-03565-008	IF-S-08	08/06/2021	KIT NEXT TO DISHWASH R	93.9	08/25/2021	
21-08-03565-009	IF-B-09	08/06/2021	HALL BY KITCHEN	<1.00	08/25/2021	
21-08-03565-010	IF-B-10	08/06/2021	HALL NEXT TO MUSIC RM/GYM	<1.00	08/25/2021	
21-08-03565-011	IF-S-11	08/06/2021	COPY RM SINK	7.42	08/25/2021	
21-08-03565-012	IF-WC-12	08/06/2021	STAFF ROOM WATER COOLER	<1.00	08/25/2021	
21-08-03565-013	IF-B-13	08/06/2021	RM 402	11.7	08/25/2021	

Environmental Hazards Services, L.L.C

Client Number: 201327
 Project/Test Address: 210133; Indian Fields; 359 Ridgr Road; Monmouth
 Junction, NJ 08852

Report Number: 21-08-03565

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-08-03565-014	IF-B-14	08/06/2021	RM 405	4.80	08/25/2021	
21-08-03565-015	IF-B-15	08/06/2021	RM 404	6.22	08/25/2021	
21-08-03565-016	IF-B-16	08/06/2021	RM 407	3.43	08/25/2021	
21-08-03565-017	IF-B-17	08/06/2021	RM 406	7.50	08/25/2021	
21-08-03565-018	IF-B-18	08/06/2021	RM 409	8.78	08/25/2021	
21-08-03565-019	IF-B-19	08/06/2021	RM 408	4.52	08/25/2021	
21-08-03565-020	IF-B-20	08/06/2021	RM 411	4.08	08/25/2021	
21-08-03565-021	IF-WC-21	08/06/2021	NEXT TO CUSTODIAL STORAGE L	<1.00	08/25/2021	
21-08-03565-022	IF-WC-22	08/06/2021	NEXT TO CUSTODIAL STORAGE LC	6.64	08/25/2021	
21-08-03565-023	IF-WC-23	08/06/2021	NEXT TO CUSTODIAL STORAGE R	1.66	08/25/2021	
21-08-03565-024	IF-B-24	08/06/2021	RM 305	4.90	08/25/2021	
21-08-03565-025	IF-B-25	08/06/2021	RM 304	3.44	08/25/2021	
21-08-03565-026	IF-B-26	08/06/2021	RM 307	3.79	08/25/2021	
21-08-03565-027	IF-B-27	08/06/2021	RM 306	5.58	08/25/2021	
21-08-03565-028	IF-B-28	08/06/2021	RM 309	3.81	08/25/2021	
21-08-03565-029	IF-B-29	08/06/2021	RM 308	4.64	08/25/2021	
21-08-03565-030	IF-B-30	08/06/2021	RM 311	4.38	08/25/2021	
21-08-03565-031	IF-WC-31	08/06/2021	HALL B/W 200 & 300 LEFT	<1.00	08/25/2021	
21-08-03565-032	IF-WC-32	08/06/2021	HALL B/2 200 & 300 LC	<1.00	08/25/2021	
21-08-03565-033	IF-WC-33	08/06/2021	HALL B/W 200 & 300 RC	<1.00	08/25/2021	

Environmental Hazards Services, L.L.C

Client Number: 201327
 Project/Test Address: 210133; Indian Fields; 359 Ridgr Road; Monmouth Junction, NJ 08852

Report Number: 21-08-03565

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-08-03565-034	IF-WC-34	08/06/2021	HALL B/W 200 & 300 RIGHT	<1.00	08/25/2021	
21-08-03565-035	IF-B-35	08/06/2021	RM 202	2.96	08/25/2021	
21-08-03565-036	IF-B-36	08/06/2021	RM 205	6.87	08/25/2021	
21-08-03565-037	IF-B-37	08/06/2021	RM 204	2.30	08/25/2021	
21-08-03565-038	IF-B-38	08/06/2021	RM 207	5.90	08/25/2021	
21-08-03565-039	IF-B-39	08/06/2021	RM 206	6.04	08/25/2021	
21-08-03565-040	IF-B-40	08/06/2021	RM 209	9.45	08/25/2021	
21-08-03565-041	IF-B-41	08/06/2021	RM 208	9.39	08/25/2021	
21-08-03565-042	IF-S-43	08/06/2021	NURSES	120	08/25/2021	
21-08-03565-043	IF-S-45	08/06/2021	MAIN OFFICE	17.8	08/25/2021	
21-08-03565-044	IF-S-46	08/06/2021	NEXT TO EXIT	<1.00	08/25/2021	

Method: EPA 200.8
 Analyst: Ailea Cabatbat
 Accreditation #: NJ VA008

Reviewed By Authorized Signatory: *Melissa Kanode*

Missy Kanode
 QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion



EHSO Laboratories
ENVIRONMENTAL HAZARDS SERVICES, LLC

ONLINE CLIENT PORTAL AVAILABLE FOR ANALYSIS RESULTS AT: www.lead4k.com

Water Chain-of-Custody Form

SHIP TO: 7469 Whitepine Rd, Richmond, VA 23237

Phone: (800) 347-4010 FAX: (804) 275-4907

Account #: 20137

Company Name: LEW CORP

Address: 183 US Highway 46

City/State/Zip: Mine Hill, NJ 07803

Phone: 908-654-8068

Email: labresults@lewcorp.com

Fax: 908-654-8069

Project Name / Collection Address: INDIAN FIELDS, 359 RIDGR ROAD

City/State/Zip: MONMOUTH JUN

Project #: 210133

Sampled by: Krishi Tanna

License # (if Required):

Water Source (Check One) Public Well

Well Tag # (if Applicable):

No.	Client Sample ID	Collection Location (Ex: Kitchen Sink)	Collection Date	Collection Time	Metals			Field Parameters		
					Lead	Copper	Other	Field pH at time of Collection	Temp. at time of Collection	Temp at Time of Receipt
1	IF-S-01	KITCHEN; NEXT TO KETTLE	8/6/2021	8:30 AM - 9:45 AM	X					
2	IF-KF-02	KETTLE FILLER; KITCHEN	8/6/2021	8:30 AM - 9:45 AM	X					
3	IF-S-03	SINK IN FRONT OF STOVE	8/6/2021	8:30 AM - 9:45 AM	X					
4	IF-IM-04	KITCHEN; ICE MACHINE	8/6/2021	8:30 AM - 9:45 AM	X					
5	IF-S-05	KITCHEN; NXT TO IM	8/6/2021	8:30 AM - 9:45 AM	X					
6	IF-S-06	KITCHEN; NEXT TO IM	8/6/2021	8:30 AM - 9:45 AM	X					
7	IF-S-07	KIT; NEXT TO DISHWASH - L	8/6/2021	8:30 AM - 9:45 AM	X					
8	IF-S-08	KIT; NEXT TO DISHWASH - R	8/6/2021	8:30 AM - 9:45 AM	X					
9	IF-B-09	HALL BY KITCHEN	8/6/2021	8:30 AM - 9:45 AM	X					
10	IF-B-10	HALL NEXT TO MUSIC RM/GYM	8/6/2021	8:30 AM - 9:45 AM	X					

Released by: KRISHI TANNA

Signature: *[Handwritten Signature]*

Date/Time: 8/6/2021

Date/Time: 8/23/21 12:24 PM

21-08-03565

Due Date:
08/30/2021
(Monday)
AE



LABORATORIES
ENVIRONMENTAL HAZARDS SERVICES, LLC

ONLINE CLIENT PORTAL AVAILABLE FOR ANALYSIS RESULTS AT: www.leadlab.com

Water Chain-of-Custody Form

SHIP TO: 2459 Whitepine Rd, Richmond, VA 23237

Phone: (800) 347-4010 FAX: (804) 275-4907

~ For Lab Use Only ~

35265

Company Name: LEW CORP

Address: 183 US Highway 46

Phone: 1998-554-8068

Email: labresults@lewcorm.com

Fax: 908-654-9069

City/State/Zip: Mine Hill, NJ 07803

City/State/Zip: MONMOUTH JUNCTION, NJ, 08852

Project Name / Collection Address: INDIAN FIELDS, 359 RIDGR ROAD

License # (If Required):

Project #: 210133

Sampled by: Krishi Tanna

Water Source: (Check One) Public Well

Well Tag # (If Applicable):

X	5 Day Turnaround	3 Day Turnaround	2 Day Turnaround	1 Day Turnaround (Call Ahead)	Metals			Field Parameters		LAB USE
					Lead	Copper	Other	Field pH at time of Collection	Temp. at time of Collection	Temp at Time of Receipt
No.	Client Sample ID	Collection Location (Ex: Kitchen Sink)	Collection Date	Collection Time						
21	IF - WC- 21	NXT TO CUSTODIAL STORAGE- L	8/6/2021	8:30 AM - 9:45 AM	X					
22	IF - WC- 22	NXT TO CUSTODIAL STORAGE- LC	8/6/2021	8:30 AM - 9:45 AM	X					
23	IF - WC- 23	NXT TO CUSTODIAL STORAGE - R	8/6/2021	8:30 AM - 9:45 AM	X					
24	IF - B - 24	RM 305	8/6/2021	8:30 AM - 9:45 AM	X					
25	IF - B - 25	RM 304	8/6/2021	8:30 AM - 9:45 AM	X					
26	IF - B - 26	RM 307	8/6/2021	8:30 AM - 9:45 AM	X					
27	IF - B - 27	RM 306	8/6/2021	8:30 AM - 9:45 AM	X					
28	IF - B - 28	RM 309	8/6/2021	8:30 AM - 9:45 AM	X					
29	IF - B - 29	RM 308	8/6/2021	8:30 AM - 9:45 AM	X					
30	IF - B - 30	RM 311	8/6/2021	8:30 AM - 9:45 AM	X					
Released by: KRISHI TANNA		Signature:		Date/Time: 8/6/2021		Date/Time: 8/23/21		Date/Time: 12:24pm		



LABORATORIES
ENVIRONMENTAL HAZARDS SERVICES, LLC

ONLINE CLIENT PORTAL AVAILABLE FOR ANALYSIS RESULTS AT: www.leadlab.com

Water Chain-of-Custody Form

SHIP TO: 7469 Juniperline Rd., Richmond, VA 23237
Phone: (800) 347-4010 FAX: (804) 275-4907

For Lab Use Only

3565

Company Name: LEW CORP
Address: 181 US Highway 46
Phone: (908) 654-8068
Email: labresults@leadlab.com
Account #: 201327
City/State/Zip: Mine Hill, NJ 07803
Fax: (908) 654-8069

Project Name / Collection Address: INDIAN FIELDS, 359 RIDGR ROAD
Project #: 210133
Sampled by: Krishi Tanna
City/State/Zip: MONMOUTH JUNCTION, NJ, 08852
License #: (if required)

Water Source: (Check One) Public Well
Well Tag #: (if applicable)

No.	Client Sample ID	Collection Location (Ex: Kitchen Sink)	Collection Date	Collection Time	Metals			Field Parameters		LAB USE
					Lead	Copper	Other	Field pH at time of Collection:	Temp. at time of Collection:	Temp at Time of Receipt:
31	IF - WC - 31	HALL B/W 200 & 300 LEFT	8/6/2021	8:30 AM - 9:45 AM	X					
32	IF - WC - 32	HALL B/W 200 & 300 - LC	8/6/2021	8:30 AM - 9:45 AM	X					
33	IF - WC - 33	HALL B/W 2008 & 300 - RC	8/6/2021	8:30 AM - 9:45 AM	X					
34	IF - WC - 34	HALL B/W 2008 & 300 - RIGHT	8/6/2021	8:30 AM - 9:45 AM	X					
35	IF - B - 35	RM 202	8/6/2021	8:30 AM - 9:45 AM	X					
36	IF - B - 36	RM 205	8/6/2021	8:30 AM - 9:45 AM	X					
37	IF - B - 37	RM 204	8/6/2021	8:30 AM - 9:45 AM	X					
38	IF - B - 38	RM 207	8/6/2021	8:30 AM - 9:45 AM	X					
39	IF - B - 39	RM 206	8/6/2021	8:30 AM - 9:45 AM	X					
40	IF - B - 40	RM 209	8/6/2021	8:30 AM - 9:45 AM	X					

Released by: KRISHI TANNA
Signature: *[Signature]*
Date/Time: 8/23/21 12:24 PM



LABORATORIES
ENVIRONMENTAL HAZARDOUS SERVICES, LLC

ONLINE CLIENT PORTAL AVAILABLE FOR ANALYSIS RESULTS AT: www.leadlab.com

Water Chain-of-Custody Form

SHIP TO: 7469 Whitepine Rd. Richmond, VA 23237

Phone: (800) 347-4010 FAX: (804) 275-4907

~ For Lab Use Only ~

Company Name: LEW CORP
Address: 181 US Highway 46
Account #: 201327
City/State/Zip: Mine Hill, NJ 07803

Phone: (908) 654-8068
Email: labresults@lewmorr.com
Fax: 908-654-8065

Project Name / Collection Address: INDIAN FIELDS; 359 RIDGR ROAD
City/State/Zip: MONMOUTH JUNCTION, NJ, 08852

Project #: 210133
Sampled By: Krishi Tanna
License #: (If Required):

Water Source: (Check One) Public Well
(Required) Well Tag #: (If Applicable):

SAMPLES NOT RCV'D KCH

No.	Client Sample ID	Collection Location (Ex: Kitchen Sink)	Collection Date	Collection Time	Metals			Field Parameters		LAB USE
					Lead	Copper	Other	Field pH at time of Collection:	Temp. at time of Collection:	
41	IF - B - 41	RM 208	8/6/2021	8:30 AM - 9:45 AM	X					
42	IF - B - 42	RM 211	8/6/2021	8:30 AM - 9:45 AM	X					
43	IF - S - 43	NURSES	8/6/2021	8:30 AM - 9:45 AM	X					
44	IF - B - 44	NURSES	8/6/2021	8:30 AM - 9:45 AM	X					
45	IF - S - 45	MAIN OFFICE	8/6/2021	8:30 AM - 9:45 AM	X					
46	IF - S - 46	NEXT TO EXIT	8/6/2021	8:30 AM - 9:45 AM	X					
7										
8										
9										
10										

Released by: KRISHI TANNA
Signature: *[Signature]*
Date/Time: 8/6/2021

Released by: KTHARRIS
Signature: *[Signature]*
Date/Time: 8/23/21 12:24pm